



PRODUCT CERTIFICATE OF REGISTRATION

Property Werx Pty Ltd T/A Wormsmart Australia

42 Production Drive, Wauchope, NSW 2446, Australia

Product Performance Testing

AS 1546.3:2017

Secondary Quality at 1500 L/day (10EP level) with nutrient reduction of 41.27% for Nitrogen and 15.55% for Phosphorus.

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
Wormsmart Plus WSP 1500PF	Optional with chlorination unit installed	TSS 18.27 mg/L BOD5 10.20 mg/L Nitrogen 41.33 mg/L Phosphorus 9.83 mg/L E coli 4.27 CFU/100mL	3 monthly if chlorine unit is attached	Pumped out of the system	Manufactured and Assembled: Tanks manufactured by Everhard Industries Assembled at 42 Production Drive, Wauchope, NSW 2446, Australia
The system took 5 weeks to achieve Secondary Level. Chlorine and worms were added during the test period.					

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units (AWTS)" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.



Managing Director



CERTIFICATION DATE:
25 January 2023

DATE OF ISSUE:
2 February 2023

EXPIRY DATE:
25 January 2028

CERTIFICATE #:
2536-2921-01